

Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



HYGIENE-INSTITUT · Postfach 10 12 55 · 45812 Gelsenkirchen / GERMANY

NEOTEX S.A.
V. Moira Str.
Industrial Area Mandra
19600 MANDRA
GREECE

Visitors-/Parcel Address:
Rotthauer Str. 21
45879 Gelsenkirchen

Telephone +49 (0) 209 9242-0
Extension +49 (0) 209 9242-277
Telefax +49 (0) 209 9242-212
E-Mail r.weiss@hyg.de
Internet www.hyg.de

Reference-No.: K-242315-14-WR/st
Contact person: Roland Weiß (Dipl.-Biol.)
Prolongation: K-173724-09-Ko/st

Gelsenkirchen, 11.04.2014

TEST CERTIFICATE according to the DVGW Code of Practice W 347 "hygienic requirements for cement-bound materials for drinking water supply"

Product: Revinex Flex 2006

Specimen: prisms (grey)

Test result:

The test specimen meets the requirements of the DVGW Code of Practice W 347 according to the test report Ref.-No: K-173723-09-Ko/st dated 24.02.2009 for the following scopes:

Scope	Products / Components	Assessment
I	mortar lining of cast iron pipes and steel pipes	---
II	concrete pipes \geq DN 300, reservoirs, cementitious coatings of reservoirs	passed
III	cement for tiles, joint filler, coating of fittings (e.g. for welding joints)	passed
IV	concrete components in protective areas of drinking water plants I, II, III	passed

This test certificate is valid beginning with the date of issue and is ending by 05.02.2019 as far as there are no changes in the formula.

The Director of the Hygiene-Institute
on behalf of

Dr. rer. nat. Andreas Koch
Head of the Dept. for water
hygienic material testing



The assessment was based on the assumption that the used starting substances and monomers used to manufacture the product may completely known and no other substances are present in the product. The validity of this document expires in case of modifications in the composition of the product or the processing conditions. The results and evaluations refer to the groups of test items. This document may not be published without our written permission only complete and unchanged or duplicated.

